



VERIFICATION OF COMPLIANCE

No.: GZES2007022912PV01

Applicant: Shenzhen SOFAR SOLAR Co., Ltd.
401, Building 4, AnTongDa Industrial Park, District 68, XingDong
Community, XinAn Street, BaoAn District, Shenzhen City,
Guangdong Province, P.R. China

Manufacturer: Shenzhen SOFAR SOLAR Co., Ltd.
401, Building 4, AnTongDa Industrial Park, District 68, XingDong
Community, XinAn Street, BaoAn District, Shenzhen City,
Guangdong Province, P.R. China

Product Name: Hybrid Inverter (Three Phase)

Product Description: Inverter used in PV system

Model No.: HYD 5KTL-3PH, HYD 6KTL-3PH;
HYD 8KTL-3PH, HYD 10KTL-3PH;

Trade Mark:



Rating:

Refer to page 2 to page 3

Intended Use:

PV System

Protection against Electric Shock:

Class I

Additional Information (if any):

IP 65

Firmware version: V2.00

Sufficient samples of the product have been tested and found to be in conformity with

Test Standard: Engineering Recommendation G98 Issue 1 - Amendment 3 March
2019

as shown in the

Test Report Number(s): GZES200702291201

This Verification of Compliance has been granted to the applicant based on the results of tests, performed by Laboratory of SGS-CSTC Standards Technical Services Co., Ltd. on sample of the above-mentioned product in accordance with the provisions of the relevant specific standards.

David Guo

Senior Technical Manager

SGS-CSTC

2020-08-27

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services, printed overleaf.

Member of SGS Group (Société Générale de Surveillance)



No.:

GZES2007022912PV01

Other information added :
Ratings

Model	HYD 5KTL-3PH	HYD 6KTL-3PH	HYD 8KTL-3PH	HYD 10KTL-3PH
PV String Input Data				
Max. DC voltage	1000V			
MPPT voltage range	180V~960V			
Full power MPPT voltage range	250V~850V	320V~850V	360V~850V	220V~850V
Max. input current	12.5A/12.5A	12.5A/12.5A	12.5A/12.5A	25A/25A
Max. short current	15A/15A	15A/15A	15A/15A	30A/30A
Battery Input Data				
Battery voltage range	180V~800V			
Battery voltage range for full load	200V~800V	240V~800V	320V~800V	200V~800V
No. of battery input	1			2
Nominal charging/discharging power	5000W	6000W	8000W	10000W
Max. charging/discharging current	25A	25A	25A	50A (25A/25A)
AC Output Data (On-grid)				
Nominal AC power	5000W	6000W	8000W	10000W
Max. AC power output to utility grid	5500VA	6600VA	8800VA	11000VA
Max. AC power from utility grid	10000VA	12000VA	16000VA	20000VA
Max. AC current output to utility grid	8A	10A	13A	16A
Rated AC current output to utility grid	7.2A	8.7A	11.6A	14.5A
Max. AC current from utility grid	15A	17A	24A	29A

David Guo
Senior Technical Manager
SGS-CSTC

2020-08-27

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services, printed overleaf.

Member of SGS Group (Société Générale de Surveillance)

No.:

GZES2007022912PV01

Nominal output voltage	3/N/PE, 230Vac			
Nominal output frequency	50Hz			
Output power factor	~1(0.8 leading to 0.8 lagging)			
AC Output Data (Back-up)				
Nominal output power	5000W	6000W	8000W	10000W
Max. output power	5500VA	6600VA	8800VA	11000VA
Rated. output current	7.2A	8.7A	11.6A	14.5A
Max. output current	8A	10A	13A	16A
Peak output current, Duration	15A, 60s	18A, 60s	24A, 60s	30A, 60s
Nominal output voltage	3/N/PE, 230Vac			
Nominal output frequency	50Hz			
Output power factor	~1(0.8 leading to 0.8 lagging)			
Operating temperature range	-30°C ~60°C			
Ingress protection	IP65			
Protective class	Class I			
Cooling method	Heat sink	Heat sink	Heat sink	Fan



David Guo
 Senior Technical Manager
 SGS-CSTC

2020-08-27

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services, printed overleaf.

Member of SGS Group (Société Générale de Surveillance)